

**PROVA DI PORTATA VENTILATORE ASSIALE**  
**AIRFLOW TEST FOR AXIAL FAN**

<b>Tipo - Type</b>	<b>Tensione di Prova Test Voltage</b>	<b>N° Prova Test No.</b>	<b>N° Progr.</b>
<b>VA01-BP70/LL-43S</b>	<b>26 V. CC. - DC.</b>	<b>758-03</b>	<b>2876</b>
<b>Note Notes</b>			

<b>Pressione Statica Static Pressure mmH<sub>2</sub>O</b>	<b>Portata Airflow m<sup>3</sup>/h</b>	<b>Corrente Assorbita Current input A</b>
<b>0,0</b>	2.798	8,8
<b>2,6</b>	2.684	9,0
<b>5,1</b>	2.579	9,3
<b>7,6</b>	2.431	9,5
<b>10,0</b>	2.300	9,7
<b>12,6</b>	2.078	9,8
<b>15,0</b>	1.881	10,0
<b>17,5</b>	1.623	10,0
<b>20,1</b>	1.386	10,1
<b>22,5</b>	1.235	10,1
<b>25,0</b>	854	10,1
<b>27,5</b>	716	10,1
<b>30,0</b>	528	10,1
<b>32,6</b>	381	10,2
<b>35,1</b>	279	10,4
<b>36,3</b>	0	10,4

<b>Note</b>	<hr/> <hr/> <hr/> <hr/>
-------------	-------------------------